



www.basiclab.com

2218 Railroad Avenue
Redding, California 96001

voice 530.243.7234
fax 530.243.7494

3860 Morrow Lane, Suite F
Chico, California 95928

voice 530.894.8966
fax 530.894.5143

COVINGTON MILL MWC DIV B
POST OFFICE BOX 144
TRINITY CENTER, CA 96091

Sampled By: DARRYL SIMMONS
Client Contact: DARRYL SIMMONS
Phone: 286-2000
Fax: -

Lab No: 18K0838
Reported: 11/21/18
System Number: 5301104
Regulator: O.D.W.
P.O. #

DRINKING WATER MONITORING

Coliform Analysis Report

Standard Total Coliform & E.coli

Analysis	Result	Chlorine (mg/l)	Sample Receipt Temp (C)*	Set Up	Read Out	Method
----------	--------	-----------------	--------------------------	--------	----------	--------

LOT 39 (18K0838-01) Routine Sampled: 11/20/18 10:00 Received: 11/20/18 12:11

Total Coliforms	Absent		9.0	11/20/18 15:30	11/21/18 09:30	Colilert
E. Coli	Absent		9.0			

Notes and Definitions

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of **Fecal coliforms** and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

* **Sample Receipt Temp:** According to 40 CFR 141.21, systems are encouraged but not required to hold samples below 10 degrees C during transit.

Approved By

Basic Laboratory, Inc
California ELAP Cert #1677 and #2718