



www.basiclab.com

2218 Railroad Avenue  
Redding, California 96001

voice 530.243.7234  
fax 530.243.7494

3860 Morrow Lane, Suite F  
Chico, California 95928

voice 530.894.8966  
fax 530.894.5143

COVINGTON MILL MWC DIV B  
POST OFFICE BOX 144  
TRINITY CENTER, CA 96091

Sampled By: DARRYL SIMMONS  
Client Contact: DARRYL SIMMONS  
Phone: 286-2000  
Fax: -

Lab No: 19C0826  
Reported: 03/20/19  
System Number: 5301104  
Regulator: O.D.W.  
P.O. #

DRINKING WATER MONITORING

## Coliform Analysis Report

### Standard Total Coliform & E.coli

Analysis	Result	Chlorine (mg/l)	Sample Receipt Temp (C)*	Set Up	Read Out	Method
LOT 122 (19C0826-01) Routine    Sampled: 03/18/19 16:30    Received: 03/19/19 11:37						

Total Coliforms	Absent		4.0	03/19/19 14:50	03/20/19 08:50	Colilert
E. Coli	Absent		4.0			

#### Notes and Definitions

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present.

The presence of **Fecal coliforms** and/or *E. coli* indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

\* Sample Receipt Temp: According to 40 CFR 141.21, systems are encouraged but not required to hold samples below 10 degrees C during transit.

Approved By

Basic Laboratory Inc  
California ELAP Cert #1677 and #2718